



**NOTES:**

1. MINIMUM WET WELL DIMENSION IS 6' DIAMETER OR 6' x 6' SQUARE.
2. MINIMUM VOLUME SHALL BE CALCULATED BASED ON A MINIMUM PUMP CYCLE TIME OF 10 MINUTES (6 STARTS PER HOUR) FOR THE SINGLE LARGEST PUMP. A LONGER PUMP CYCLE TIME SHALL BE USED IF REQUIRED BY THE PUMP MANUFACTURER.



HENRY COUNTY WATER AUTHORITY

**TYPICAL SANITARY  
SEWAGE LIFT STATION  
WET WELL**

REVISED: 01/01/2018

SCALE: N.T.S.

DETAIL NO.

**S30**