



NOTES:

1. DUCTILE IRON PIPE FOR SANITARY SEWAGE FORCE MAINS SHALL BE BEDDED IN ACCORDANCE WITH ANSI/AWWA C150/A21.50 AND ANSI/AWWA C151/A21.51, TYPE 3 LAYING CONDITION.
2. MINIMUM DEPTH OF COVER SHALL BE 5'-0" UNLESS OTHERWISE APPROVED BY HCWA.



HENRY COUNTY WATER AUTHORITY

**DUCTILE IRON SANITARY
SEWAGE FORCE MAIN
TRENCH DETAIL**

REVISED: 02/07/2018

SCALE: N.T.S.

DETAIL NO.

S02