


NOTES:

1. C900 POLYVINYL CHLORIDE (PVC) PIPE FOR SANITARY SEWAGE FORCE MAINS SHALL BE BEDDED IN ACCORDANCE WITH AWWA C605, TYPE 3 LAYING CONDITION.
2. MINIMUM DEPTH OF COVER SHALL BE 5'-0" UNLESS OTHERWISE APPROVED BY HCWA.
3. MAXIMUM DEPTH OF COVER SHALL BE 16'-0".
4. TRACER WIRE SHALL BE INSTALLED ON ALL SANITARY SEWAGE FORCE MAINS.



HENRY COUNTY WATER AUTHORITY

**C900 PVC SANITARY
SEWAGE FORCE MAIN
TRENCH DETAIL**

REVISED: 02/07/2018

SCALE: N.T.S.

DETAIL NO.

S03