



NOTES:

1. MANHOLES LOCATED OUTSIDE OF PAVEMENT SHALL HAVE WATER TIGHT BOLT-DOWN LIDS AND 2 FEET ABOVE FINISHED GRADE WITH FRAME CAST INTO THE CONE SECTION.
2. MANHOLES SHALL HAVE A MINIMUM DROP OF 0.10 FEET FROM INFLUENT INVERT TO EFFLUENT INVERT.



HENRY COUNTY WATER AUTHORITY

**STANDARD SANITARY
SEWER MANHOLE**

REVISED: 09/11/2018

SCALE: N.T.S.

DETAIL NO.

S07