



NOTES:

1. OUTSIDE DROPS REQUIRED WHEN INSIDE DROP IS GREATER THAN 2 FEET.
2. MANHOLES LOCATED OUTSIDE OF PAVEMENT SHALL HAVE WATER TIGHT BOLT-DOWN LIDS AND 2 FEET ABOVE FINISHED GRADE WITH FRAME CAST INTO THE CONE SECTION.
3. PIPE ENCASED IN CONCRETE SHALL BE WRAPPED WITH MINIMUM 10 MIL PLASTIC.



HENRY COUNTY WATER AUTHORITY

SANITARY MANHOLE WITH OUTSIDE DROP

REVISED: 09/11/2018

SCALE: N.T.S.

DETAIL NO.

S08