



NOTES:

1. ALL JOINTS AROUND EXISTING AND PROPOSED SEWER LINE SHALL BE GROUTED WATERTIGHT.
2. AFTER DOGHOUSE MANHOLE CONSTRUCTION IS COMPLETE, TOP HALF OF EXISTING SEWER LINE SHALL BE CUT OUT USING A METHOD APPROVED BY THE HCWA INSPECTOR.
3. MANHOLES LOCATED OUTSIDE OF PAVEMENT SHALL HAVE WATER TIGHT BOLT-DOWN LIDS AND 2 FEET ABOVE FINISHED GRADE WITH FRAME CAST INTO THE CONE SECTION.



HENRY COUNTY WATER AUTHORITY

**SANITARY SEWER
DOGHOUSE MANHOLE**

REVISED: 09/11/2018

SCALE: N.T.S.

DETAIL NO.

S09