



NOTES:

- MANHOLES LOCATED OUTSIDE OF PAVEMENT SHALL HAVE WATER TIGHT BOLT-DOWN LIDS AND 2 FEET ABOVE FINISHED GRADE WITH FRAME CAST INTO THE CONE SECTION.



HENRY COUNTY WATER AUTHORITY

**SHALLOW SANITARY
SEWER MANHOLE**

REVISED: 09/11/2018

SCALE: N.T.S.

DETAIL NO.

S10