



**NOTES:**

1. PIPE USED FOR CREEK CROSSINGS SHALL BE DUCTILE IRON PIPE UNLESS OTHERWISE APPROVED BY HCWA. AT LEAST ONE JOINT BEYOND THE END OF CASING SHALL BE RESTRAINED, OR AS REQUIRED BY HCWA.
2. MINIMUM DEPTH OF COVER SHALL BE 12 INCHES.
3. REFER TO DETAIL S16 FOR GRAVITY SEWER AND S38 FOR FORCE MAIN CASING DIAMETERS.
4. PLACE STONE RIP-RAP APPROXIMATELY 5 FEET UPSTREAM AND 5 FEET DOWNSTREAM FROM CENTERLINE OF PIPE ALONG CREEK BED.



HENRY COUNTY WATER AUTHORITY

**CREEK CROSSING**

REVISED: 09/11/2018

SCALE: N.T.S.

DETAIL NO.

**S17**