


NOTES:

1. SERVICE LINES SHALL BE STUBBED OUT TO 17 FEET BEHIND THE BACK OF CURB AND SHALL BE NO MORE THAN 10 FEET DEEP.
2. A WATER TIGHT CAP SHALL BE INSTALLED ON THE END OF THE LINE.
3. SERVICE LINES HAVING LESS THAN 5 FEET OF COVER SHALL BE DUCTILE IRON PIPE.
4. PLUMBING CONTRACTOR SHALL TIE ON TO SERVICE LINE USING STANDARD PVC FITTINGS OR "DONUT" CONNECTION WITH GROUT.



HENRY COUNTY WATER AUTHORITY

SEWER SERVICE LINE LATERAL

REVISED: 09/19/2018

SCALE: N.T.S.

DETAIL NO.

S18