



SHALLOW SLOPES

STEEP SLOPES

NOTES:

1. SERVICE LINES SHALL BE DUCTILE IRON PIPE STUBBED OUT TO 17 FEET BEHIND THE BACK OF CURB AND SHALL BE NO MORE THAN 10 FEET DEEP.
2. FITTINGS SHALL BE RESTRAINED.
3. SERVICE LINE SHALL BE PLUGGED WITH A WATERTIGHT CAP.



HENRY COUNTY WATER AUTHORITY

SERVICE LATERAL FOR SEWER LINES 16 FEET DEEP AND GREATER

REVISED: 01/01/2012

SCALE: N.T.S.

DETAIL NO.

S19