



**NOTES:**

1. GREASE INTERCEPTOR SHALL HAVE A MINIMUM CAPACITY OF 1,500 GALLONS AND A MAXIMUM CAPACITY OF 3,000 GALLONS. IF REQUIRED CAPACITY IS GREATER THAN 3,000 GALLONS, MULTIPLE GREASE INTERCEPTORS SHALL BE USED.
2. CONCRETE DESIGN STRENGTH SHALL BE 4,000 PSI @ 28 DAYS.
3. GREASE INTERCEPTOR SHALL BE HS-20 LOAD RATED.



HENRY COUNTY WATER AUTHORITY

**GREASE INTERCEPTOR**

REVISED: 02/16/2018

SCALE: N.T.S.

DETAIL NO.

**S33**