


SELECT EARTH BACKFILL PLACED IN 6" LIFTS AND COMPACTED TO MINIMUM 90 PERCENT STANDARD PROCTOR, (ASTM D698) OR AS REQUIRED BY HCWA

SELECT EARTH BACKFILL PLACED IN 6" LIFTS AND COMPACTED TO MINIMUM 90 PERCENT STANDARD PROCTOR, (ASTM D698) OR AS REQUIRED BY HCWA

FLAT BOTTOM TRENCH (I.E. UNDISTURBED EARTH) WITH SELECT EARTH BACKFILL LIGHTLY CONSOLIDATED TO CENTERLINE OF PIPE

NOTES:

1. DUCTILE IRON PIPE FOR WATER MAINS SHALL BE BEDDED IN ACCORDANCE WITH ANSI/AWWA C150/A21.50 AND ANSI/AWWA C151/A21.51, TYPE 2 LAYING CONDITION.
2. MINIMUM DEPTH OF COVER SHALL BE 4'-0" UNLESS OTHERWISE APPROVED BY HCWA.



HENRY COUNTY WATER AUTHORITY

**WATER LINE
TRENCH DETAIL**

REVISED: 09/11/2018

SCALE: N.T.S.

DETAIL NO.

W02