


**NOTES:**

1. LONGER ANCHOR COUPLINGS MAY BE USED WHEN REQUIRED. IF ANCHOR COUPLINGS ARE NOT USED, VALVE SHALL BE RODDED TO THE TEE AND HYDRANT SHALL BE RODDED TO THE VALVE USING A MINIMUM OF TWO (2) 3/4" THREADED RODS ON EACH CONNECTION.



HENRY COUNTY WATER AUTHORITY

**TYPICAL FIRE HYDRANT ASSEMBLY**

REVISED: 01/31/2018

SCALE: N.T.S.

DETAIL NO.

**W04**