


**NOTES:**

1. ALL FITTINGS AND VALVES SHALL BE RESTRAINED.



HENRY COUNTY WATER AUTHORITY

**FIRE HYDRANT IN  
CUL-DE-SAC**

REVISED: 01/31/2018

SCALE: N.T.S.

DETAIL NO.

**W05**