


NOTES:

1. ALL BURIED VALVES AND FITTINGS SHALL HAVE MJ FLANGES AND SHALL BE RESTRAINED WITH RESTRAINED JOINT GLANDS.



HENRY COUNTY WATER AUTHORITY

**10" OMNI F2 COMPACT
FIRELINE METER**

REVISED: 09/11/2018

SCALE: N.T.S.

DETAIL NO.

W18