



NOTES:

1. NO PERMANENT STRUCTURES SHALL BE ALLOWED WITHIN 5 FEET.
2. TYPICAL INSTALLATION MAY BE MODIFIED AT THE DISCRETION OF HCWA.
3. MINIMUM OF 4 TEST COCKS.



HENRY COUNTY WATER AUTHORITY

**REDUCED PRESSURE
ZONE DETAIL**

REVISED: 11/13/2018

SCALE: N.T.S.

DETAIL NO.

W26